



CERTIFICATE

This certificate is being issued under Maharashtra Fire Prevention and safety Measures Act- 2006 **Guru Mishri Ayurved College and Smt. Matoshri Badambai Motilalji Desarda Ayurved Hospital, Shelgaon, Tal.Badnapur, Dist. Jalna** Gut No. / C.T.S. No. **310**, House No. - at Shelgaon, Tal. BADNAPUR, Dist. JALNA inspection of above mentioned premises has been conducted by **SONWANE** on dated **15/03/2025**.

Findings of the inspection are as follows

1	Co2 Kg Nos
2	D. C. P. Fire Extinguisher Kg Nos
3	A. B. C. Fire Extinguisher6..... Kg04. Nos
4	Water Co2 Fire Extinguisher Kg Nos
5	Mechanical Foam Fire Extinguisher Kg Nos
6	House Reel100. Ft03. Nos
7	Fire Docket Send/Water Nos
8	Fire Service in-late hydrant System in rule outlet fire pump, HP Booster Pump, Underground Water Tank 35,000 Ltr. Over Head Water Tank 10,000 Ltr.		
9	Stair Cases for Emergency		Yes /- No
10	Emergency Door		Yes /- No
11	Fire Alarm		Yes /- No
12	House Box, Containing House Pipe & Branch in the front side of the premises		Yes /- No

Hence this certificate is issued
This Certificate is Valid up to **31st March 2026**



[Signature]
CHIEF FIRE OFFICER
MUNCIPAL CORPORATION,
JALNA



[Signature]
PRINCIPAL
GURU MISHRI AYURVED COLLEGE
SHELGAON, JALNA